

UE DECLARATION OF CONFORMITY

No CE/EN/0618/V4/2023/0545

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

SURGE ARRESTOR

Type/types: (1) **KSD-T1+T2 275/150 3P**, (2) **KSD-T1+T2 275/200 M**,
(3) **KSD-T1T2 275/200 3P+N**, (4) **KSD-T1+T2 275/50 1P**,
(5) **KSD-T1T2 275/200R3P+N**, (6) **KSD-T1+T2 275/50 M**,
(7) **KSD-T2 275/120 3P**, (8) **KSD-T2 275/160 3P+N**,
(9) **KSD-T2 275/40 1P**, (10) **KSD-T2 275/40 M**,
(11) **KSD-T1+T2 275/60 M**

Trade mark:

IDEAL^{TS}
by Kanlux

Basic parameters:

Un: 230V~; Uc: 275V~; (1)- (6): In: 25kA, I_{max}: 50kA; (7)- (10): In: 20kA, I_{max}: 40kA;
(12): In: 30kA, I_{max}: 60kA

Batch or serial number:

#DL

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU**Directive (RoHS) – 2011/65/EU, (EU)2015/863**

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 61643-11:2012 +A11:2018**EN IEC 63000:2018**

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.**NWP/WO; ID 0618; S.CE/0545****Radzionków, 23.03.2023**

Kanlux S.A.
Kierownik Laboratorium Badawczego

Krzysztof Żurek

Kanlux SA
Kierownik ds. Wdrożeń
i Certyfikacji Produktów

Adam Wabnic

(name, function) (signature)

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | **kanlux.com**