



## EU DECLARATION OF CONFORMITY

No CE/EN/1237/V1/2024/1136

Name and address of the manufacturer:

**KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

- (1) **MOVEMENT SENSOR**
- (2) **PRESENCE DETECTOR**

Type/types:

- (1) **SENSQUARE-W, SENSQUARE-B,**
- (2) **SENTO-O-WT-W, SENTO-O-WT-B**

### Kanlux

Trade mark:

Basic parameters:

220-240V~; 50Hz; class II; (1) – IP54; (2) – IP44/IP20;  
(1) – max 8m; max 1200VA; GLS – max 1200W, LED – max 180W, CFL – max 720W  
(2) – max 10m; max 2000VA; GLS – max 1000W, LED – max 300W, CFL – max 100W

Batch or serial number: #CL

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

- Directive (LVD) – 2014/35/EU**
- Directive (EMC) – 2014/30/EU**
- Directive (RoHS) – 2011/65/EU, (EU)2015/863**

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

- EN 60669-1:2018**
- EN IEC 60669-2-1:2022 +A11:2022**
- EN IEC 55015:2019 +A11:2020**
- EN IEC 61000-3-2:2019 +A1:2021**
- EN 61000-3-3:2013 +A1:2019**
- EN 61547:2009**
- EN IEC 63000:2018**

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.

**NWP/WO; ID 1237; S.CE/1136**

Radzionków, 29.01.2024

**Kanlux S.A.** Kierownik Laboratorium Badawczego  
**Kanlux S.A.** Dyrektor Działu Technicznego  
**Kanlux SA** Kierownik ds. Wdrożeń i Certyfikacji Produktów

Krzysztof Żurek Dariusz Stanczyk Adam Wabnic

(name, function) (signature)

**Kanlux SA** 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | [kanlux.com](http://kanlux.com)