

35852 OS-M8D-WW-RST-W-P1

Recessed - Mounted LED Office Fixture

5905339358523




















GENERAL DATA:

Colour: white

Place of assembly: Recessed mount in the ceiling

Place of application: Indoors

Minimum distance from the illuminated object: 0,5m

Compatible with a dimmer: no

The product is not suitable to be covered with a heat-insulating

material: yes Length [mm]: 595 Width [mm]: 595 Height [mm]: 34

Integrated LED light source: yes

TECHNICAL DATA:

Rated voltage [V]: 220-240 AC Rated frequency [Hz]: 50 Maximum power [W]: 39W

Class of protection against electric shock:

Lampshade material: plastic Diode type: LED SMD

Luminous flux of the light fitting [lm]: 5400

Colour temperature: Warm white

Correlated colour temperature [K]: 3000 Colour consistency in McAdam ellipses: ≤3

Colour rendering index: 80 Service life [h]: 50000

Luminous-flux-retention factor at the end of rated service life :

L90B10

Number of on/off cycles: ≥30000

Lighting angle [°]: 80

Ambient temperature range to which the product can be

exposed: 5÷25 **Shade type**: louvre

Enclosure material: Metal


Connection type: Self-clamping block

Range of sections of wires used [mm²]: $1,5 \div 2,5$

Lamp-heating time [s]: ≤1 Lamp-ignition time [s]: ≤0,5 Rodzaj soczewki [°]: 80

IP class: 20 **UGR**: ≤16

Date of issue: 10.07.2024, 09:36








35852 OS-M8D-WW-RST-W-P1

Recessed - Mounted LED Office Fixture



LOGISTIC DATA:

Unit of measurement: unit Packaging method: 1

Number of units in the secondary packaging: 1


Number of units in the packaging: 1

ADDITIONAL INFORMATION:

• 5 years Warranty under the terms of the warranty statement, available on our website

KANLUX S.A. (kat 35852) OS-M8D-WW-RST-W-P1 / Krzywa rozsyłu światła (biegunowo)

Oprawa: KANLUX S.A. (kat 35952) OS-M8D-WW-RST-W-P1 Lampy: 4 x OS-M8D-WW-RST





We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.

